

52. SHOWERS

Bathing and Shower Facilities

Where facilities for bathing are provided for the public, clients or employees, including showers or bathtubs, at least one shower or bathtub and support facilities such as lockers, and not less than 1 percent (1%) of facilities, shall be accessible. **1115B.2 4.23.8**

Orientation - Where, within the same functional area, two or more accessible showers are provided, there shall be at least one shower constructed opposite hand from the other or others (i.e., one left hand controls vs. right hand controls). **1115B.4.4.3**

Sprayer unit alternative. Except within guest rooms and suites in hotels, motels and similar transient lodging establishments where accessible shower facilities are provided in areas subject to excessive vandalism, in lieu of providing the fixed flexible hose, two wall mounted shower heads shall be installed. Each shower head shall be installed so that it can be operated independently of the other and shall have swivel angle adjustments, both vertically and horizontally. One shower head shall be located at a height of 48" above the floor. **1115B.4.4.6**

ROLL-IN SHOWER - 60" MIN. WIDTH x 30" MIN. DEPTH SHOWER STALL DESIGN

- _____ A. The roll-in shower is a minimum 60" in width between wall surfaces and a minimum 30" in depth with a full opening width on the long side. **1115B.4.4.1.1 4.21.2 Fig. 104**
- _____ B. A minimum 36" x 60" clear floor space adjoins the compartment. **1115B.4.4.1.1 4.21.2 Fig. 104**
- _____ C. Water valve control is single lever design. **1115B.4.4.4 4.27.4**
- _____ D. Centerline of control is located on the back wall of the compartment adjacent to the seat within a reach range of no less than 19" and no more than 27" from the seat wall. **1115B.4.4.4.1 Fig. 104**
- _____ E. The centerline of the shower controls are located at 39" to 41" above the shower floor. **1115B.4.4.4 Fig. 104**
- _____ F. The force required to operate the controls is 5 lb. maximum. **1115B.4.4.4 4.27.4**
- _____ G. The controls are operable with one hand and do not require tight grasping, pinching or twisting of the wrist. **1115B.4.4.4 4.27.4**
- _____ H. 5 lb. maximum operating force. **1115B.4.4.4 4.27.4**
- _____ I. A flexible hand held sprayer unit with a hose at least 60" long that can be used both as a fixed shower head and as a hand-held shower is provided and mounted such that the top of the mounting bracket is at a maximum height of 48" above the shower floor. **1115B.4.4.5 4.21.6 Figs. 104**